

Our water system tested a minimum of 1 sample(s) per month in accordance with the Total Coliform Rule for microbiological contaminants. With the microbiological samples collected, the water system collects disinfectant residuals to ensure control of microbial growth.

| Disinfectant | Date | Highest RAA | Unit | Range | MRDL | MRDLG | Typical Source |
|--------------|------|-------------|------|-------|------|-------|----------------|
|--------------|------|-------------|------|-------|------|-------|----------------|

Regulated Contaminants

In the tables below, we have shown the regulated contaminants that were detected. Chemical Sampling of our drinking water may not be required on an annual basis; therefore, information provided in this table refers back to the latest year of chemical sampling results.

| Unregulated Contaminant Monitoring Rule (UCMR) | | | Collection Date of RV | | Highest Value (RV) | | Range of Sampled Results | | Unit |
|--|-------------|--|---------------------------------------|--|--------------------|-----|--------------------------|--|------|
| Lead and Copper | Period | 90TH Percentile: 90% of your water utility levels were less than | Range of Sampled Results (low - high) | | Unit | AL | Sites Over AL | Typical Source | |
| COPPER, FREE | 2021 - 2024 | 0.141 | 0.00506 - 0.499 | | ppm | 1.3 | 0 | Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives | |
| LEAD | 2021 - 2024 | 0.66 | 0.24 - 1.28 | | ppb | 15 | 0 | Corrosion of household plumbing systems; Erosion of natural deposits | |

| Disinfection Byproducts | Sample Point | Period | Highest LRAA | Range | Unit | WCL | MCLG | Typical Source | |
|-------------------------------|---------------|-------------|--------------|-------------|------|-----|------|---|--|
| TOTAL HALOACETIC ACIDS (HAAs) | 215 S JACKSON | 2023 - 2024 | 8 | 8.39 - 8.39 | ppb | 60 | 0 | By-product of drinking water disinfection | |
| THM | 204 BRYAN CT | 2023 - 2024 | 18 | 17.6 - 17.6 | ppb | 80 | 0 | By-product of drinking water chlorination | |

| Regulated Contaminants | Collection Date | Highest Value | Range | Unit | MCL | MCLG | Typical Source | |
|------------------------|-----------------|---------------|--------|------|-----|------|---|--|
| ARSENIC | 12/5/2023 | 1.07 | 1.07 | ppb | 10 | 0 | Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes | |
| BARIUM | 12/5/2023 | 0.0935 | 0.0935 | ppm | 2 | 2 | Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits | |
| CHROMIUM | 12/5/2023 | 0.48 | 0.48 | ppb | 100 | 100 | Discharge from steel and pulp mills; Erosion of natural deposits | |
| FLUORIDE | 12/5/2023 | 0.18 | 0.18 | ppm | 4 | 4 | Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories | |
| NICKEL | 12/5/2023 | 0.005 | 0.005 | MG/L | 0.1 | 0.1 | | |

| Radiological Contaminants | Collection Date | Highest | Range | Unit | MCL | MCLG | Typical Source | |
|---------------------------|-----------------|---------|-------|------|-----|------|----------------|--|
|---------------------------|-----------------|---------|-------|------|-----|------|----------------|--|